

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7270-1615:108

Page 1 of 1

**CATEGORY:** Heat Detectors

**LISTEE:** Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

**DESIGN:** Models F220-135, -135F, and -190F fixed temperature heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

F220-135	135° fixed temperature with 15° rate of rise
F220-135F	135° fixed temperature
F220-190F	190° fixed temperature

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as heat detectors for use with separately listed compatible fire alarm control units and Model F220-B6 series detector bases (CSFM Listing No. 7300-1615:105). Refer to listee's Installation Instruction Manual for details.

07-21-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*